



0401

CERTIFICATE OF CALIBRATION

Ricardo Energy & Environment, 18 Blythswood Square, Glasgow, G2 4BG

Telephone 01235 753642

Authorised Signatories:

D Hector ✓
S Stratton

Signed: 

Date of Issue: 26th July 2017

Certificate Number: 3762

Page 1 of 3

Customer Name and Address: Scottish Government
Water, Air, Soils and Flooding Division
Environmental Quality Directorate
Scottish Government
Victoria Quay
Edinburgh
EH6 6QQ

Description: Calibration factors for Glasgow City Council's Anderson, Abercromby St, Broomhill, Burgher Street, Byres Road, Dumbarton Road, Nithsdale Road and Waulkmillglen Reservoir air monitoring stations.

Site / Date Test Carried Out	Species	Analyser Serial No.	Zero Response ¹	Uncertainties ppb	Calibration Factor ²	Uncertainties %	Converter eff. (%) ³
Anderston 5 th May 2016	NO _x	529b-229	1.0	3.1	1.1864	3.5	98.4
	NO		0.0	2.6	1.1754	3.5	
	SO ₂	835b-324	2.0	2.6	1.1538	2.9	
Anderston 24 th June 2016	NO _x	529b-229	1.0	3.4	1.2989	3.5	98.5
	NO		1.0	3.4	1.2935	3.5	
	SO ₂	835b-324	-1.0	2.7	1.0630	2.9	
Burgher Street 16 th August 2016	NO _x	CM1105	-0.1	2.5	0.8823	3.5	99.7
	NO	0006	-0.2	2.5	0.8815	3.5	
Byres Road 20 th June 2016	NO _x	M1362	2.0	2.9	1.2332	3.5	100.5
	NO	-M575	0.0	2.6	1.2207	3.5	

The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor k=2 providing a level of confidence of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements.

This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except Ricardo Energy & Environment using its Registered Office. Ricardo Energy & Environment is a trading name of Ricardo-AEA Ltd.

Head Office
Gemini Building,
Fermi Avenue,
Harwell,
Oxon
OX11 0QR

Shoreham Technical Centre
Shoreham-by-Sea
West Sussex
BN43 5FG

Registered in England No.
08229264

Tel: +44 (0)1235 753 000

VAT Registration No.
GB 212 8365 24

Site / Date Test Carried Out	Species	Analyser Serial No.	Zero Response ^{e1}	Uncertainties ppb	Calibration Factor ²	Uncertainties %	Converter eff. (%) ³
Dumbarton Road 21 st June 2016	NO _x	404b-174	-1.0	3.0	1.2989	3.5	98.5
	NO		-2.0	3.0	1.3077	3.5	

Waulkmillglen Reservoir 21 st June 2016	NO _x	697b-309	0.0	2.8	1.2815	3.5	96.8
	NO		-1.0	2.9	1.2865	3.5	
	O ₃	M1620-M334	-1.3	3	1.0448	3.3	

Site / Date Test Carried Out	Species	Analyser Serial No.	Parameter	Specified Value	Measured Value	Deviation %	Uncertainty %
Dumbarton Road 21 st June 2016	TEOM PM ₁₀	25458	Main Flow ⁴	3.00	2.55	-15.1	2.25
			Aux Flow ⁴	13.67			
			Total Flow	16.67	16.61	-0.4	2.25
			k ₀ ⁵	13085	13075	-0.1	1.00

Waulkmillglen Reservoir 21 st June 2016	TEOM PM ₁₀	23919	Main Flow ⁴	3.00	3.26	8.7	2.25
			Aux Flow ⁴	13.67	16.62	7.0	2.25
			Total Flow	16.67	17.88	7.3	2.25
			k ₀ ⁵	13426	13493	0.5	1.00

Abercromby Street 24 th June 2016	FDMS PM ₁₀	26459	Main Flow ⁴	3.00	3.08	2.8	2.25
			Aux Flow ⁴	13.67			
			Total Flow	16.67	15.69	-5.9	2.25
			k ₀ ⁵	15641	15930	1.8	1.00

Anderston 5 th May 2016	FDMS PM ₁₀	21650	Main Flow ⁴	3.00	3.39	13.1	2.25
			Aux Flow ⁴	13.67	14.61	6.9	2.25
			Total Flow	16.67	18.00	8.0	2.25
			k ₀ ⁵	13818	13961	1.0	1.00

Anderston 24 th June 2016	FDMS PM ₁₀	21650	Main Flow ⁴	3.00	3.10	3.4	2.25
			Aux Flow ⁴	13.67			
			Total Flow	16.67	16.06	-3.6	2.25
			k ₀ ⁵	13818	13824	0.0	1.00

Broomhill 20 th June 2016	FDMS PM ₁₀	26460	Main Flow ⁴	3.00	3.04	1.3	2.25
			Aux Flow ⁴	13.63			
			Total Flow	13.67	16.48	-1.1	2.25
			k ₀ ⁵	14989	15061	0.5	1.00

Burgher Street 16 th August 2016	FDMS PM ₁₀	140ab2212 79806	Main Flow ⁴	3.00	3.10	3.3	2.25
			Aux Flow ⁴	13.67			
			Total Flow	16.67	16.98	1.9	2.25
			k ₀ ⁵	16036	16188	0.9	1.00

Site / Date Test Carried Out	Species	Analyser Serial No.	Parameter	Specified Value	Measured Value	Deviation %	Uncertainty %
Byres Road 20 th June 2016	FDMS PM ₁₀	140ab2603 10602	Main Flow ⁴	3.00	3.09	3.0	2.25
			Aux Flow ⁴	13.67			
			Total Flow	16.67	16.87	1.2	2.25
			k ₀ ⁵	12912	12849	-0.5	1.00

Nithsdale Road 21 st June 2016	FDMS PM ₁₀	26457	Main Flow ⁴	3.00	3.09	2.9	2.25
			Aux Flow ⁴	13.67			
			Total Flow	16.67	15.40	-7.6	2.25
			k ₀ ⁵	13832	14167	2.4	1.00

The gaseous ambient analysers listed above have been tested for zero response, calibration factor, linearity and converter efficiency (NO_x analysers only) by documented methods. The factors have been calculated using certified gas standards. The particulate analysers listed above have been tested for sample flow rates and k₀ (where appropriate) by documented methods. Note that the test results are valid on the day of test only, as analyser drift over time cannot be quantified. All results for gaseous species are given in ppb (parts per billion) mole fractions or ppm (parts per million) mole fractions.

¹The zero response is the zero reading on the data logging system of the analyser when audit zero gas was introduced to the analysers under test.

²The calibration factor is the multiplying factor required to scale the reading on the data logging system of the analyser into reported concentration units (ppb for NO, NO_x, SO₂, O₃ and ppm for CO. Where 1 ppm = 1000 ppb). It should be used in conjunction with the zero response. A corrected concentration is calculated using the following equation:

Concentration = F (Output - Zero Response)

Where F = Calibration Factor provided on this certificate
 Output = Reading on the data logging system of the analyser
 Zero Response = Zero Response provided on this certificate

³Converter eff. is the measured efficiency of the NO₂ to NO converter within the oxides of nitrogen analyser under test.

⁴The measured main flow rate (where applicable) is the flow rate through the sensor unit of the TEOM particulate analyser under test. The measured aux flow rate (where applicable) is the flow rate through the bypass tubing of the TEOM particulate analyser under test. The measured total flow rate is the total flow rate through the particulate analyser under test. Units of flow are l.min⁻¹. Where flow rates are highlighted in bold, it indicates that measurements were not made at the analyser sample inlet. These measurements therefore may not accurately reflect analyser performance in normal operation.

⁵The calculated k₀ value (TEOM analysers only) is the calculated k₀ spring constant based on tests undertaken with filters of known weight. The % deviation indicates the closeness of the calculated result to the manufacturer's specified k₀ value.

The calibration results shaded are those that fall out with our scope of accreditation, all other results on this certificate are not UKAS accredited, but have been included for completeness.